



NOT TO SCALE

NOTES:

1. ALL SIDEWALKS CROSSING DRIVEWAYS OR ALLEYS SHALL HAVE THE SAME THICKNESS AS THE APRON.
2. ONE PANEL ON EACH SIDE OF APRON CROSSING SHALL BE SAME THICKNESS AS THE APRON.
3. CONTROL JOINTS TO BE SAWCUT AT 1/8" WIDE. 1/4" TOOLED WILL ONLY BE ACCEPTED WHERE SAWCUT JOINTS ARE NOT POSSIBLE.
4. PED RAMP CONCRETE SHALL BE A MINIMUM OF 6" THICK.
5. PED RAMP TRUNCATED DOMES SHALL BE A MINIMUM OF 6' WIDE.
6. CONCRETE SHALL BE MNDOT 3F52 OR APPROVED EQUAL.
7. MEMBRANE CURING COMPOUND SHALL BE CLEAR TK2519 DCWB, AMS 3754 CLEAR OR APPROVED EQUAL.