


## PLAN VIEW (MINUS GRATE) NOT TO SCALE



- 1. HDPE ADJUSTING RINGS ARE REQUIRED.
- 2. LADTECH GLUE (PER INSTRUCTIONS) SHALL BE APPLIED BETWEEN EACH HDPE ADJUSTING RING. CONSTRUCT ½" CONCRETE GROUT BETWEEN CONCRETE CONE AND HDPE RINGS. IF THE OPENING IS OFFSET FROM THE STRUCTURE CONCRETE RINGS MAY BE REQUIRED BY THE ENGINEER. MINIMUM ½" MORTAR BETWEEN CASTING, CONCRETE ADJUSTING RINGS, AND STRUCTURE. (NON-SHRINKING GROUT REQ.) INFI-SHIELD SHALL BE INSTALLED IN CONJUNCTION WITH ADJUSTING RINGS AND CASTING ASSEMBLY.
- 3. FRAME, GRATE AND CURB BOX TO BE NEENAH FOUNDRY NO. R-3067 TYPE R. USE TYPE V GRATE FOR HIGH FLOW AREAS AND TYPE VB IN LOW POINTS. DRIVEWAY INLETS USE NEENAH R-3290-A. SURMOUNTABLE CURB USE NEENAH R-3501-TB.
- 4. PREFORMED HOLES AND RUBBER BOOTS REQUIRED ON NEW STRUCTURES FOR DRAIN TILE CONNECTIONS. NON-PRECAST OPENINGS SHALL BE CORE DRILLED AND RUBBER BOOTED.
- 5. STRUCTURE MUST BE PRECAST

